

Heating System Summary

January 22, 2022

Project Information

Project #:

Name:

Location:

Notes:

Design based on information provided by the customer and generalized R-values are used for heat loss summary. For a 100% accurate calculations

exact building specifications must be given (eg. R-values of walls, floors,

ceilings, windows, doors etc)

The hydronic designer is not responsible for an improperly installed existing/new hydronic heating system. Please ensure all local codes and proper piping

practices are used when installing hydronic heating systems.

Project Summary Load Calculation Method:

Calgary, Alberta Design Location: -22.0 °F Outdoor Temperature: Floorplans / Levels: Main Floor 4,152 ft² Loft 1.159 ft² Total Area: 5.311 ft²

Total Circuit Lengths: Barrier PEX 1/2"

Total RH Circuits:

Total Manifolds:

Total Zones:

Fluid Type:

5,358 ft

Component Losses: Infiltration/Ventilation: 71.000 Btu/hr 32,112 Btu/hr

Radiant Back Losses: 8,012 Btu/hr Total Heating Load: 111,123 Btu/hr

Radiant Heating: 100,585 Btu/hr Radiant Back Losses: 8.012 Btu/hr

Glycol

30% Propylene

23

2

Other: Total Heating Load:

2.527 Btu/hr 111,123 Btu/hr

Total Tubing Volume: 49.32 USG Glycol Volume (30%): 14.80 USG

Zone Heating Summary

Zone #	Gross Area	Construction	Heating Types	RH¹ Circuits	Total Tubing	Manifolds	Flowrate	Head Loss (Circuit Only)	RH Load²	Supplemental	Zone Load³
Zone 101	4,152	Embedded Slab	RH,OTH	18	4,237	3	9.91	7.2	89,359	2,527	91,886
Zone 201	1,159	Concrete Thin Slab	RH	5	1,121	1	2.42	3.9	22,954	0	22,954

⁽¹⁾ Complete circuits assigned to this zone. (2) Total Radiant heating load for rooms in zone, including all panel backloss. (3) Total load for zone including all panel backloss. Does not account for reclaimed loss within building envalope.

CSA F280-12

Room Heating Summary (By Construction Type)

Embedded Slab

Zone #	Room Name	Heating Type	Floor Area	Heated Area	Manifold #	Tube Size	RH Circuits ¹	Tube Spacing	Tubing In Room	Floor Cover RV	Required Temp.	Unit RH Load	RH Load ²	Supplemental	Total Load ³
Zone 101	Bed Hall	RH	56	56	n/a	n/a	0		64	0.5	0	7.4	417	0	417
Zone 101	Bedroom 1	RH, OTH	255	255	Manifold 4	1/2"	2		262	0.5	135	36.7	9,355	1,149	10,504
Zone 101	Bedroom 2	RH	203	203	Manifold 4	1/2"	1		209	0.5	134	34.6	7,026	0	7,026
Zone 101	Bedroom 3	RH	187	187	Manifold 4	1/2"	1		180	0.5	126	29.4	5,504	0	5,504
Zone 101	Bedroom Bath	RH	71	42	Manifold 4	1/2"	1		43	0.5	134	21.6	899	0	899
Zone 101	Den	RH, OTH	147	147	n/a	n/a	0		149	0.5	0	31.3	4,596	793	5,390
Zone 101	Ensuite	RH	233	233	Manifold 3	1/2"	1		235	0.5	114	23.7	5,510	0	5,510
Zone 101	Garage	RH	896	896	Manifold 2	1/2"	4		947	0.5	120	26	23,265	0	23,265
Zone 101	Hallway	RH	152	82	n/a	n/a	0		102	0.5	0	8.1	661	0	661
Zone 101	Kitchen/Living/ Dining	RH	1,047	1,047	Manifold 3	1/2"	6		1,055	0.5	112	20.1	21,032	0	21,032
Zone 101	Laundry	RH	76	76	Manifold 3	1/2"	1		75	0.5	94	0	2	0	2
Zone 101	Mech Room	RH	94	94	n/a	n/a	0		174	0.5	0	12	1,133	0	1,133
Zone 101	Mudroom	RH	48	48	n/a	n/a	0		58	0.5	0	0.1	2	0	2
Zone 101	Owners Suite	RH	224	224	Manifold 3	1/2"	1		214	0.5	128	30.6	6,845	0	6,845
Zone 101	Pantry	RH	80	80	Manifold 3	1/2"	11		79	0.5	134	14.8	1,174	0	1,174
Zone 101	Powder Room	RH, OTH	56	56	Manifold 3	1/2"	1		58	0.5	134	34.7	1,938	585	2,523

⁽¹⁾ Circuits assigned to this room. Leaders from other rooms may not be counted. (2) Includes panel backloss. (3) Total load including panel backloss. Does not account for reclaimed loss within building envalope.

Concrete Thin Slab

Zone #	Room Name	Heating Type	Floor Area	Heated Area	Manifold #	Tube Size	RH Circuits ¹	Tube Spacing	Tubing In Room	Floor Cover RV	Required Temp.	Unit RH Load	RH Load ²	Supplemental	Total Load ³
Zone 201	Loft	RH	1,071	1,001	Manifold 1	1/2"	5		1,091	0.5	110	22.9	22,954	0	22,954

⁽¹⁾ Circuits assigned to this room. Leaders from other rooms may not be counted. (2) Includes panel backloss. (3) Total load including panel backloss. Does not account for reclaimed loss within building envalope.

Manifold Summary

Manifold Name	# Zones	# Circuits	Flowrate	Head Loss¹	Required Temp.	Supplied Temp.	Temp Drop	Manifold Type	Control Type	# Actuators	S/R Length²	S/R Pipe
Manifold 1	1	5	2.42	4.9	110	120	20	None Selected	Manifold	0	-	-
Manifold 2	1	4	2.45	6.8	120	120	20	None Selected	Manifold	0	-	-
Manifold 3	1	10	4.82	7.3	134	135	20	None Selected	Manifold	0	-	-

Length = ft Area = ft2 Head Loss = ft water

Temperature = °F RH = Radiant Floor Heating

Flowrate = USGPM

Air Flow = cfm BB = Baseboard FA = Forced Air

Heat Loss = Btu/hr

Unit Heat Loss = Btu/hr·ft² OTH = Other Heating SM = Snowmelt $Rv = hr \cdot ft^2 \cdot °F/btu$ N = Not Heated

Created Using LoopCAD 2017 (1/23/2022) Version:17.0.0280 R Name:Dmitri Bobko

Heating System Summary

Project #: January 22, 2022

Manifold 4	1	4	2.63	8.2	135	135	20	None Selected	Manifold	0	-	-
Total	2	23	12.33	8.2	135	-	20	-	-	0	-	-

⁽¹⁾ Total Head loss includes manifold, circuits and supply/return piping if specified. (2) S/R Length = one way

Disclaimers

With the permission of Canadian Standards Association, material is reproduced from CSA Standard, CSA F280-12 (Revision 1, 2014.03), Determining the Required Capacity of Residential Space Heating and Cooling Appliances which is copyrighted by Canadian Standards Association, 178 Rexdale Blvd., Toronto, Ontario, M9W 1R3, www.shopcsa.ca. While use of this material has been authorized, CSA shall not be responsible for the manner in which the information is presented, nor for any interpretations thereof.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIFY CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.