

SANYO Commercial Solutions

HVAC Solutions Group 1165 Allgood Rd., N.E., Suite 22 Marietta, GA 30062

Tel: 770.977.8510 www.sanyohvac.com

INSTALLATION INSTRUCTIONS

Sanyo Universal Wind Shield (Baffle) Part Number: WINDB-1

CONTENTS INCLUDED: 1 baffle, 6 screws with washers and spacers.

GENERAL: This wind shield is sized so it will fit onto all Sanyo outdoor mini splits and the mini-ECOi models. It is made to be placed on the fan discharge side of the unit. See the drawing below. One Wind Shield will be used for 9,000 to 36,000 BTU outdoor units while 42,000 BTU and larger outdoor units require two shields.

INSTALLATION PROCEDURES:

- The pre drilled holes (on baffle) will match up with pilot holes on the 26, 30, 36 and 42,000 BTU Mini splits, also the ECOi Mini models.
- ➤ For the 9,000 24,000 BTU mini splits and the Flexi Multi models some of the pre dilled holes will not be able to be used.
 - Pre drill ¼ inch holes into the plastic wind shield flange where necessary.
 - Shift the wind shield left/right and or up/down as needed.
 - BEFORE DRILLING OR SCREWING INTO THE UNIT, MAKE SURE THERE WILL BE NO CONTACT WITH REFRIGERENT TUBING OR ELECTRICAL WIRES. CHECK FOR CLEARENCE.

