

Bank 1			
Cell values at end of discharge (21hrs)			
Cell #	voltage	% of highest cell	
25	2.983	96.16%	!
26	2.954	95.23%	!
27	3.102	100.00%	
28	3.017	97.26%	
29	2.982	96.13%	!
30	3.098	99.87%	
31	3.060	98.65%	
32	3.090	99.61%	
16	2.929	94.42%	!
32	3.066	98.84%	
31	2.853	91.97%	!
30	3.038	97.94%	
29	3.073	99.07%	
28	3.073	99.07%	
27	3.096	99.81%	
26	3.089	99.58%	
	3.102	<< max value	