





















### Conext ComBox



- System Performance
  - Battery
  - Loads
  - Grid
  - Solar
  - Generator
  - PV & AC Daily Summary
  - Battery Bank Daily Summary
  - PV Inverters
- System Devices
  - CSW (0)
  - MPPT (0)
    - Settings**
    - Events
  - BATTMON (0)
  - SCP (0)
  - AGS (0)
- ComBox Configuration

|                             |                                   |     |   |
|-----------------------------|-----------------------------------|-----|---|
| Absorption Time             | <input type="text" value="300"/>  | min |   |
| Default Battery Temperature | <input type="text" value="Warm"/> |     |   |
| Nominal Battery Voltage     | <input type="text" value="24"/>   | V   |   |

 [Custom Battery Settings](#)

| Parameter                       | Value   |       |   |
|---------------------------------|---|-------|---|
| Equalize Support                | <input type="text" value="Equalization Not Allowed"/> |       |       |
| Equalize Voltage Set Point      | <input type="text" value="32.0"/>                     | V     |       |
| Bulk/Boost Voltage Set Point    | <input type="text" value="28.8"/>                     | V     |       |
| Absorption Voltage Set Point    | <input type="text" value="28.8"/>                     | V     |       |
| Float Voltage Set Point         | <input type="text" value="27.0"/>                     | V     |       |
| Battery Temperature Coefficient | <input type="text" value="-58"/>                      | mV/°C |   |

2016/05/04 07:37