

Bank 0	divergance in MV	High	Low
charged to 3.6 and rested 12 hours			
3PM - 5 minutes into discharge	10	3.434	3.424
6PM - 3 hrs into discharge	7	3.306	3.299
11PM - 8 hrs into discharge	12	3.296	3.284
11pm 3-17 Inverter off			
10am 3-18 inverter on			
1PM - 11 hrs into discharge	7	3.264	3.257
5PM - 15 hrs into discharge	8	3.261	3.253
9PM - 19 hrs into discharge	9	3.249	3.240
11PM - 21 hrs into discharge	8	3.225	3.217
11pm 3-17 Inverter off			
9:30am 3-18 inverter on			
10:30 22 hrs into discharge	10	3.203	3.193
12pm 23.5 hrs into discharge	12	3.167	3.155
2pm 25.5 hrs into discharge	115	3.133	3.018
2:30pm 26 hrs into discharge	201	3.085	2.884
2:30pm 26 hrs into discharge	221	3.066	2.845