

Bank 0			
Cell values at end of discharge (26hrs)			
Cell #	voltage	% of highest cell	
9	2.995	97.68%	
10	3.042	99.22%	
11	2.983	97.29%	
12	3.012	98.24%	
13	2.851	92.99%	!
14	3.029	98.79%	
15	3.050	99.48%	
16	2.984	97.33%	
1	3.066	100.00%	
2	2.973	96.97%	
3	2.962	96.61%	
4	2.957	96.44%	
5	2.933	95.66%	
6	2.845	92.79%	!
7	3.022	98.56%	
8	3.011	98.21%	
	3.066	<< max value	